

SECTION 01506
DIVERSION PUMPING

PART 1 GENERAL

1.01 DEFINITIONS

- A. Diversion-pumping: Installation and operation of bulkheads, plugs, hoses, piping, and pumps required to maintain sewer flow and prevent backups and overflows.

1.02 SYSTEM DESCRIPTION

- A. Provides continuous sewer service to users of sewer systems while maintenance or construction operations are in progress, by diverting flow around construction locations. Maintain sewer flow to prevent backup or overflow onto streets, yards, and unpaved areas or into buildings, adjacent ditches, storm sewers, and waterways. Do not divert sewage outside of sanitary sewer system.
- B. When pumps are operating, have an experienced operator on site to monitor operation, adjust pumps, make minor repairs to system, and report problems.

1.03 SUBMITTALS

- A. Conform to requirements of Section 01330 - Submittals Procedures.
- B. For systems that bypass sanitary sewer line segments of 42-inch diameter to larger, submit a Diversion Pumping Plan prior to installation. Show location, number and size of pumps, number, location, size and type of hoses or rigid piping, and location of downstream, discharge; and special features where pipes or hoses cross roadways, temporary trenches, support bridges.

1.04 SCHEDULING

- A. When the City operates or maintains diversion pumping in construction areas, coordinate construction activities with Public Works.
- B. Cease operation of diversion pumping when approved by Public Works.

PART 2 PRODUCTS

2.01 MATERIALS

- A. Design piping, joints and accessories to withstand at least twice maximum system pressure or 50psi, whichever is greater.
- B. Use self-priming type or submersible electric pumps, with a working pressure gauge on the discharge.

PART 3 EXECUTION

3.01 FIELD QUALITY CONTROL

- A. During diversion pumping, do not allow sewage to leak, dump, or spill into or onto areas outside of existing sanitary sewer systems.
- B. In the event of an accidental spill or overflow, immediately stop discharge and take action to clean up and disinfect spill. Promptly notify Public Works so required reporting can be made to the Texas Commission on Environmental Quality (TCEQ) and the Environmental Protection Agency (EPA).

3.02 CLEANING

- A. When diversion-pumping operations are complete, drain sewage within piping into sanitary sewers prior to disassembly.

END OF SECTION