



GENERAL NOTES

1. THE CONTRACTOR SHALL PLACE FLOWABLE FILL A MINIMUM OF 1-FT. AROUND WALLS, FROM THE BOTTOM OF BASE UP TO THE BOTTOM OF CONCRETE COLLAR. PER SPEC. 02081 AND 02082.
2. TOP SECTION SHALL BE FLAT TOP WITH CONCENTRIC HOLE.
3. WALL REINFORCEMENT SHALL BE DESIGNED BY ENGINEER FOR CAST-IN-PLACE MANHOLES.
4. PROVIDE WATERTIGHT SEAL BETWEEN PRECAST CONCRETE ADJUSTMENT RINGS AND MANHOLE COVER FRAME, AROUND MANHOLE, HDPE RINGS, AND MANHOLE RISER JOINTS PER SPEC 02081, 02082, AND 02083 (GATORWRAP OR APPROVED EQUAL).
5. INTERIOR MANHOLE WALLS SHALL BE COATED WITH AN APPROVED LINER PER SPEC 02081 AND 02082 IN AREAS WHICH EXPERIENCE CORROSION. .



STANDARD DETAIL 02081.1

MANHOLES

TECHNICAL SPECIFICATION SECTIONS 02081, 02082, & 02083

ENGINEERING AND PUBLIC WORKS

SCALE: N.T.S.

DATE: 12/07/2022

DSGN. BY: ENG

DRAWN BY: TGW

SHEET NO. 1 of 1