



GENERAL NOTES

1. ALL DEAD END STREETS MUST HAVE APPROPRIATE BARRICADE AND HEADER CURB.
2. THE POSTS SHALL BE SET IN A MINIMUM OF 1' DEEP CLASS "A" CONCRETE (UNLESS OTHERWISE SHOWN ON PLANS) IN ACCORDANCE WITH ITEM, "PORTLAND CEMENT CONCRETE". CONCRETE SHALL BE SUBSIDIARY TO THE BID ITEM.
3. WHERE SOLID ROCK IS ENCOUNTERED OR WHERE SHOWN ON THE PLANS, THE DIAMETER OF THE HOLES SHALL BE APPROXIMATELY 12 INCHES, THE BACKFILLING SHALL BE WITH A COHESIONLESS MATERIAL, AND EMBEDMENT DEPTH SHALL BE 1'-6" OR MORE AS DIRECTED BY THE CITY ENGINEER.

STANDARD DETAIL 01504

END OF STREET BARRICADE - TYPE 1
TECHNICAL SPECIFICATION SECTION 01504

ENGINEERING AND PUBLIC WORKS

SCALE: N.T.S.

DATE: 12/07/2022

DSGN. BY: ENG

DRAWN BY: JRS

SHEET NO. 1 of 1